



## MASTER FITTER ASSESSMENT – LVT

### OVERVIEW OF PRACTICAL ASSESSMENT

Applicant will be required to correctly apply smoothing compound to an area of approximately 4m<sup>2</sup>.

Applicant will be required to install 4mm ply wood to the fitting bay (approx. 5m<sup>2</sup>).

Applicant will be required to install Square tiles/strip wood at 45°, incorporating a 3mm feature strip in the main field. The installation must also have a inset boarder made up of two feature strip widths (6mm).The installation will have an out-fill of approximately 100mm straight lay tile/strip wood without feature strip. The fitting bay will incorporate a low level radiator. The area must be treated as a “live installation”. All relevant pre-installation checks must be observed.

Applicant will be required to bring with them all tools necessary to complete the installation (to include all PPS and safety equipment)

All materials will be provided, however, applicant may supply own materials at the discretion of the assessor.